

Certificate Number: ESV120039/00



Certificate of Approval

This is to certify that the Director of Energy Safety has approved the electrical equipment described hereunder.

Registered Declarant: ABB Australia Pty Limited
601 Blackburn Road
Notting Hill VIC 3168

Required Marking: ESV120039

Electrical equipment covered by this approval must comply in all respects with the approved article, and prior to being supplied or offered for supply, must be clearly and indelibly marked with the required marking indicated above, or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled.

Any modifications to the electrical equipment or its place of manufacture must be approved by Energy Safe Victoria prior to the equipment being supplied or offered for supply.

Notification must be given to Energy Safe Victoria of any change to the name or address of the holder of the certificate within 20 business days.

ARTICLE DETAILS

Electrical Equipment:	Prescribed Residual Current Device Residual Current Device
Relevant Standards:	AS/NZS61009
Expiry Date:	6/02/2017
Conditions of Approval:	

A handwritten signature in black ink, appearing to read "I. J. Flewson".

Certificate Number: ESV120039/00



Approval details

RCBO, 1P+N, single module, 240VAC, 6;10;16;20A, Type AC, Curve C, 30mA

Model	DSN201
Rated at	Input: 240VAC, 6;10;16;20A, 50Hz
Trade Name	DSN201
Comments	Single pole 240VAC 6kA RCBO, 1P+N, Curve C, Type AC, 30mA sensitivity, 19mm wide.

A handwritten signature in black ink, appearing to read "P. J. Flewson".